



# WOOD RODGERS

May 13, 2015  
Project No. 2892.040

Mr. Eric Jones  
Joy Engineering  
600 Magnolia Way  
Reno, NV 89506

RE: Rip Rap Testing  
USA Parkway Quarry

Dear Mr. Jones:

Table 1 below presents a summary of recent testing performed on rip rap samples delivered from your USA Parkway Quarry.

Table 1 - Rip Rap Test Summary

Apparent Specific Gravity	5/5/15	ASTM C97	2.63*
Absorption (percent)	5/5/15	ASTM C127	3.58**

\*2.5 Minimum, \*\*4.2 Maximum

Both tests meet the requirements of Tables 200.07.03-II and 200.07.04-II of the 2007 Standard Specifications for Public Works Construction, Section 200.07 Rip Rap, regarding apparent specific gravity and absorption.

We appreciate the opportunity to perform our laboratory testing services for you. Please contact our office should you have any related questions or comments.

Sincerely,

**Wood Rodgers, Incorporated**

*Brian T. Clark*  
Brian T. Clark, PE  
Laboratory Manager

*Mischelle J. Smith*  
Mischelle J. Smith, PE  
Associate  
PE Number 6972  
Expires 06/30/2016